

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 475

Dated: 09/07/2025

It is certified that an inspection team headed by Smt. Imleshwari Kawre from sub division - keolari PHED inspected the St. Norbert School, Mandla Road Keolari on 09.07.2025 and on the basis of Water Test Report (Attached) bearing no. U2653328530593472 dated 09.07.2025 of PHED Keolari (PHED Lab) certified that the St. Norbert School Mandla Road Keolari has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till One year



Assistant Engineer

Signature with Seal: PHE Sub Division KeolariName : Smt. Imleshwari KawreDesignation : Assistant EngineerName & Address of the Office : Public health

Engineering Department
sub division - keolari
District - M.P Seoni
m.p

To,
 St. Norbert School, Keolari
 Mandla Road, Seoni

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



MANAGER
 ST. NORBERT SCHOOL
 KEOLARI, DIST-SEONI (M.P.)
 CBSE AFFL. NO. 1031118



PRINCIPAL
 ST. NORBERT SCHOOL
 KEOLARI, DIST-SEONI (M.P.)
 CBSE AFFL. NO. 1031118

Sub Div. Lab Keolari

PHE sub div. keolari (Test Address only)

[Download](#) [Print](#)

Test report

Sample
Id:

U2653328530593472

User Information

Name: THOMAS CHANDY Mobile: 9617957378

Email: 51088@cbseshiksha.in Pin Code: 480994

Full Address: Village- Keolari , Gram Panchayat- Keolari, Block- KEOLARI, District- Seoni, State- Madhya Pradesh

Sample description

Source of Sample: ST NORBERT SCHOOL MANDLA ROAD KEOLARI Village: Keolari

Gram Panchayat: Keolari Block: KEOLARI

District: Seoni State: Madhya Pradesh

Address: Remarks:

Latitude: 0 Longitude: 0

Date & time of sample collection

08.07.2025 | 02:01:00 PM

Date & time of sample received in lab

08.07.2025 | 02:06:00 PM

Date & time of sample analysed

09.07.2025 | 03:20:00 PM

Date & time of report generation

10.07.2025 | 12:09:47 PM



MANAGER
ST. NORBERT SCHOOL
KEOLARI, DIST-SEONI (M.P.)
CBSE AFFL. NO. 1031118



PRINCIPAL
ST. NORBERT SCHOOL
KEOLARI, DIST-SEONI (M.P.)
CBSE AFFL. NO. 1031118

Test results

A No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit in absence of alternate source as per BIS 10500	Test result value	Method of Analysis	Remarks
1	Calcium (as Ca)*	mg/l	75	200	85.000	Titrimetric method	
2	Chloride (as Cl)*	mg/l	250	1000	25.000	Titration method	
3	Colour*	Hazen units	5	15	0.000	Visual comparison method	
4	E. coli	CFU/100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	MFT	
5	Fluoride (as F)	mg/l	1	1.5	0.370	Visual comparison method	
6	Iron (As Fe)	mg/l	1	No Relaxation	0.150	Visual comparison method	
7	Magnesium (As Mg)*	mg/l	30	100	44.500	Titration method	
8	Nitrate (as NO ₃)	mg/l	45	No Relaxation	5.000	Visual comparison method	
9	pH*	NA	6.5-8.5	No Relaxation	7.170	Instrumental method	
10	Sulphate (as SO ₄)	mg/l	200	400	24.800	Turbidimetric method	
11	TDS*	mg/l	500	2000	147.400	Instrumental method	
12	Total Alkalinity (as Calcium Carbonate)*	mg/l	200	600	45.000	Titration method	
13	Total coliform	CFU/ 100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	MFT	
14	Total Hardness (As CaCO ₃)*	mg/l	200	600	100.000	EDTA Titrimetric method	
15	Turbidity*	NTU	1	5	1.300	Nephelometric method	

Note:

- 1)*Indicates parameters that are NABL accredited.
- 2)This test results related to the sample tested above
- 3)The report shall not to be reproduced in full without approval of authority
- 4)This is the end of the report

Data prepared by

Chemist: (Raju Kumare)

Microbiologist: (Raju Kumare)

Raj Kumar
Lab Chemist
9/07/2024

for *Raj Kumar*
Authorised Signatory
B.L. Harinkhede (Test Lab Incharge)

*****This is an electronically generated report and does not require a signature*****

Jai Jeevan Mission aims at potable tap water supply to every home

Bara
MANAGER
ST. NORBERT SCHOOL
KEOLARI, DIST-SEONI (M.P.)
CBSE AFFL. NO. 1031118

Fr. Thomas
PRINCIPAL
ST. NORBERT SCHOOL
KEOLARI, DIST-SEONI (M.P.)
CBSE AFFL. NO. 1031118



कार्यालय खंड चिकित्सा अधिकारी,
सिविल अस्पताल केवलारी जिला सिवनी म0प्र0

कार्यालय दूरभाष - 07694235439

Email - bmokeolari730@gmail.com

क्रमांक / बीएमओ / 2025 / 514

केवलारी दिनांक 9.7.2025

प्रमाण-पत्र

प्रमाणित किया जाता है कि विकास खंड केवलारी के अन्तर्गत सेंट नार्बर्ट स्कूल मंडला रोड पर संचालित किया जा रहा है, जिनके अनुरोध करने पर मेरे द्वारा स्कूल का सर्वेक्षण किया गया है सर्वेक्षण के दौरान स्कूल का परिसर स्वच्छ एवं साफ पाया गया स्कूल प्रशासन विधार्थियों के स्वास्थ्य के प्रति जागरूक है विधार्थियों के स्वास्थ्य खराब होने पर प्राथमिक उपचार हेतु सिविल अस्पताल केवलारी में प्रशासन द्वारा स्वयं एवं तुरंत लाया जाता है जिनका उपचार मेरे द्वारा किया जाता है।

प्रमाणित किया सो सत्य हैं ।

खण्ड चिकित्सा अधिकारी
सिविल अस्पताल केवलारी

BLOCK MEDICAL OFFICER
CIVIL HOSPITAL KEOLARI

MANAGER
ST. NORBERT SCHOOL
KEOLARI, DIST-SEONI (M.P.)
CBSE AFFL. NO. 1031118

PRINCIPAL
ST. NORBERT SR. SEC. SCHOOL
KEOLARI, DIST-SEONI (M.P.)
CBSE AFFL. NO. 1031118